

City of Kuna Street Light Requirements

Excerpt from Kuna City Code Title 6 Chapter 4 Section 2

6-4-2: - REQUIRED PUBLIC IMPROVEMENTS

- T. *Street lighting:* Street lights shall be installed within the subdivision at intersections, fire hydrants, cul-de-sacs and other types of turn around, pedestrian shelters and bus stops and according to the approved lighting plan. The subdivider shall place lighting facilities a maximum spacing of two hundred fifty (250) feet and proportionately dispersed throughout the interior and exterior of the subdivision. The street lighting shall alternate along the course of the subdivision roadways from one (1) side of the road to the other at maximum two hundred fifty-foot intervals. The subdivider shall conform to street lighting standards, as adopted by resolution of the city council. Lighting facilities shall be designed and installed according to "Dark Skies" standards. Lighting facilities will be reviewed by city staff to assure they are energy efficient, and if not, the subdivider shall provide an alternative lighting product acceptable to the city. The street lighting facilities shall be of a design standard that makes them easily exchangeable with minimal replacement cost outlay.

For the complete code section follow the link below:

https://library.municode.com/id/kuna/codes/code_of_ordinances?nodeId=TIT6SURE_C H4IMST_6-4-2REPUIM

Idaho Power Street Light Requirements

Schedule 41 - Street Lighting Service/Meters:

Follow the Link Below and Go to Pages 21 – 25:

<https://puc.idaho.gov/fileroom/cases/elec/IPC/IPCE1908/20190601FINAL%20APPROVED%20TARIFFS.PDF>